

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Unique Public Sr. Sec. School
Gadi Garh, Opp. Karan Bagh
Jammu

No: JDJF&ES/FPI 2476

Dated: 27.05.2021

Sub: Provisional Fire Safety Certificate.
Ref: Your letter No UPSSS/GG/21/180 dated. 21.05.2021
Sir,

The inspection of above said school was got carried out and found that the management has installed only First Aid Fire Extinguishers in their school premises, besides this one underground water storage tank of 30 KL capacity is also available. The school is about 05 km away from Fire & Emergency Station Gandhi Nagar Jammu and is approachable for fire tenders in case of any emergency. Since the school is already functioning as such, the management can proceed ahead for operation provisionally subject to strict adopt the following fire safety precautionary measures in letter and spirit forthwith:-

1. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
2. Hose Reel Hoses as per BIS specifications connected with the terrace tank of 5000 Liters capacity should be provided in the school building. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of the building are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near water storage tank with dual electric supply for feeding the Hose Reel Hoses.
3. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the fire fighting equipments installed in the school are functioning.
4. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
5. The corridor of the building shall not be used for any kind of storage.
6. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
7. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
8. At present school is triple storey, as such no addition/alteration should be made by the school management in the existing structure without prior permission from this department.
9. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. The validity of this provisional clearance shall remain enforce for one year and same needs to be renewed yearly after inspection/checking of entire fire fighting system (i.e existing as well as proposed) by this department.

Yours Sincerely


Joint Director

Fire & Emergency Services
Jammu Range, Jammu